



MOD : CVX/8T

Production code : BERVDI8000PRO3F-C

09/2024



Air density (γ): 1.20 kg/m³


Installation type "A": free inlet, free outlet

12000 m³/h fan test chamber according to AMCA 210/05 fig. 12

Free field Lp(A) measurements at 1 m according to ISO 3746:2011

Fan type:	BERVDI 8000 PRO (cliente:1396)	Motor code:	201101U	Motor T.H.:	YES OUT
Test nr.:	2929	Motor power [W]:	1000	Capacitor [μF]:	-
Date:	2018/06/06	Motor poles:	4	Fan max. abs. current [A]:	3,8/2,2
Power supply[V]:	230/400 3~	Mot. prot. class:	IP55	Fan max. abs. power [W]:	1180
Frequency [Hz]:	50	Mot. ins. class:	F		

ErP status: Not subjected to ErP Regulation



Air density (γ): 1.20 kg/m³



Installation type "A": free inlet, free outlet

12000 m³/h fan test chamber according to AMCA 210/05 fig. 12

Free field Lp(A) measurements at 1 m according to ISO 3746:2011

Fan type:	BERVDI 8000 PRO (cliente:1396)	Motor code:	201101U	Motor T.H.:	YES OUT
Test nr.:	2929	Motor power [W]:	1000	Capacitor [μF]:	-
Date:	2018/06/06	Motor poles:	4	Fan max. abs. current [A]:	3,8/2,2
Power supply[V]:	230/400 3~	Mot. prot. class:	IP55	Fan max. abs. power [W]:	1180
Frequency [Hz]:	50	Mot. ins. class:	F		

ErP status: Not subjected to ErP Regulation



Air density (γ): 1.20 kg/m³


Installation type "A": free inlet, free outlet

12000 m³/h fan test chamber according to AMCA 210/05 fig. 12

Free field Lp(A) measurements at 1 m according to ISO 3746:2011

Fan type:	BERVDI 8000 PRO (cliente:1396)			Motor code:	201101U	Motor T.H.:	YES OUT
Test nr.:	2929	Motor power [W]:	1000	Capacitor [μF]:	-	Fan max. abs. current [A]:	3,8/2,2
Date:	2018/06/06	Motor poles:	4	Fan max. abs. power [W]:	1180		
Power supply[V]:	230/400 3~	Mot. prot. class:	IP55				
Frequency [Hz]:	50	Mot. ins. class:	F				

ErP status: Not subjected to ErP Regulation



Air density (γ): 1.20 kg/m³

Installation type "A": free inlet, free outlet


12000 m³/h fan test chamber according to AMCA 210/05 fig. 12

Free field Lp(A) measurements at 1 m according to ISO 3746:2011

Fan type:	BERVDI 8000 PRO (cliente:1396)	Motor code:	201101U	Motor T.H.:	YES OUT
Test nr.:	2929	Motor power [W]:	1000	Capacitor [μF]:	-
Date:	2018/06/06	Motor poles:	4	Fan max. abs. current [A]:	3,8/2,2
Power supply[V]:	230/400 3~	Mot. prot. class:	IP55	Fan max. abs. power [W]:	1180
Frequency [Hz]:	50	Mot. ins. class:	F		

ErP status: Not subjected to ErP Regulation

Setup for unit noise test



Noise test setup is according to ISO 3746:2011 Standard.

A microphone, placed at 1 meter from the air inlet and 1 meter from the ground, gets the sound pressure levels in different unit operating conditions.

Test data are then mathematically revised in order to get the A-weighted free-field total sound pressure levels Lp(A) of the unit.

The Lp(A) value in dB(A) is available on CMC documentation.

Add 11 dB(A) to the sound pressure level Lp(A) value to get the correspondent sound power level Lw(A).